



RISK CONTROL PLAN CITATIONS

HOT WATER CAPACITY

CODE REQUIREMENT [310:257-9-8(b) & 310:257-9-14(a)]

310:257-9-8. Quantity and availability, capacity ^{Pf}

(b) Hot water generation and distribution systems shall be sufficient to meet the peak hot water demands throughout the food establishment.

[Source: Added at 23 Ok Reg 2358, eff 6-25-06; Amended at 33 Ok Reg 1520, eff 9-11-16]

310:257-9-14. Handwashing facility, installation

(a) ^{Pf} A handwashing lavatory shall be equipped to provide water at a temperature of at least 38°C (100°F) through a mixing valve or combination faucet.

[Source: Added at 23 Ok Reg 2358, eff 6-25-06]